

**RESOLUTION DIRECTING WORK TO CLIFFSIDE PAVING  
UNDER THE BIENNIAL MISCELLANEOUS REPAIR CONTRACT**

---

**MOTIONED BY:** Barrera

**SECONDED BY:** Guzman

**WHEREAS**, the North Hudson Sewerage Authority (hereinafter "Authority") is a public body, duly formed under the Sewerage Authorities law, constituting Chapter 138 of the Laws of New Jersey of 1946, as amended (Chapter 14A of Title 40 of the New Jersey Statutes Annotated) and possesses the powers set forth therein; and

**WHEREAS**, the Authority has awarded a biennial contract for the Miscellaneous Repair to combined sewers of various configurations, lengths, sizes materials and their appurtenances; and

**WHEREAS**, the Authority awarded such a Miscellaneous Repair Contract as required by the New Jersey Contract laws to Cliffside Paving; and

**WHEREAS**, it is the recommendation of the Authority Engineer that Cliffside Paving, be directed to commence the work as detailed in the attached report prepared by OMI (July Project), identified as "Exhibit A", for an amount of money estimated at approximately \$95,125.00; and

**WHEREAS**, the Chief Financial Officer has certified that funding is available through the Authority's Fiscal Year 2022-2023 Operating Budget.

**NOW, THEREFORE, BE IT RESOLVED** that Cliffside Paving be directed to proceed with the work as herein noted.

**DATED: JULY 21, 2022**

**RECORD OF COMMISSIONERS' VOTE**

	YES	NO	ABSENT
Commissioner Kappock	x		
Commissioner Marotta	x		
Commissioner Gardiner	x		
Commissioner Friedrich	x		
Commissioner Guzman	x		
Commissioner Velazquez			x
Commissioner Barrera	x		
Commissioner Zucconi	x		
Commissioner Assadourian			x

**THIS IS TO CERTIFY THAT THIS RESOLUTION WAS DULY ADOPTED BY THE NORTH HUDSON BOARD OF COMMISSIONERS ON JULY 21, 2022.**




---

**SECRETARY**

July 10, 2022

Fredric J. Pocci  
Authority Engineer  
North Hudson Sewerage Authority  
1600 Adams Street  
Hoboken, New Jersey 07030

Subject: Miscellaneous Repair Biennial Contracts: 2022-2024  
July 2022 Project

Dear Mr. Pocci:

The Miscellaneous Repair Biennial Contracts: 2022-2024 will be awarded to Cliffside Paving LLC. On March 17, 2022. OMI has prepared a repair project for July 2022. The estimated costs of these repairs are based on unit prices bid by Cliffside Paving LLC.

Attached is the scope of work and estimated construction costs for the Miscellaneous Repair Biennial Contracts: 2022-2024 – July 2022 Project. OMI developed the list based on field inspections and resident concerns, and has estimated quantities and costs for the project.

The proposed July 2022 Project consists of three repairs in Hoboken, five repairs in Union City, one repair in Weehawken, and nine repairs in West New York. The Construction costs for the eighteen repairs is estimated to be \$95,125.00 and repairs should be completed in four weeks.

If you have any questions or require additional information, please contact me.

Sincerely,



Philip G. Reeve  
Assistant Project Director

Enclosures

Cc:

Don Conger, Jacobs OMS  
Kevin Wynn, HMM

**COMBINED SEWER - MISCELLANEOUS REPAIRS BIENNIAL CONTRACT 2022 - 2024**

**PROJECT SUMMARY**

**July 2022 PROJECT**

**NORTH HUDSON SEWERAGE AUTHORITY**

**7/10/2022**

**OWNER:** NORTH HUDSON SEWERAGE AUTHORITY  
1600 ADAMS STREET  
HOBOKEN, NJ 07030

**CONTRACTOR** Cliffside Paving LLC.  
75 Lincoln Avenue  
Cliffside Park NJ

<b>PROJECT</b>	<b>DESCRIPTION</b>	<b>ESTIMATED COST</b>
1	Hoboken Project #1 - #914 Garden Street - Severely worn manhole casting	\$2,875.00
2	Hoboken Project #2 - 10th Street & Willow Ave NW corner - open joint in catch basin lateral	\$5,000.00
3	Hoboken Project #3 - 6th Street & Bloomfield ave NW corner - Collapsed catch basin lateral	\$5,000.00
4	Union City Project #1 - 27th Street & Bergenline SW corner - Collapsed catch basin lateral	\$5,000.00
5	Union City Project #2 - #112 49th St - Collapsed catch basin lateral	\$5,000.00
6	Union City Project #3 - 7th Street & West Street - Open joint in Mainline	\$15,000.00
7	Union City Project #4 - #4312Bergenline NW corner - Open joint in lateral	\$5,000.00
8	Union City Project #5 - 26th Street & Central Ave NW corner - collapsed catch basin lateral	\$5,000.00
9	Weehawken Project #1 - #422 Gregory St - Collapsed catch basin lateral	\$5,000.00
10	West New York Project #1 - #427 62nd Street North CB - Collapsed catch basin	\$5,000.00
11	West New York Project #2 - 50th Street & Park Ave - Severely worn manhole casting	\$2,875.00
12	West New York Project #3 - #5010 Park Ave - Severely worn manhole casting	\$2,875.00
13	West New York Project #4 - 51st Street & Park Ave - Severely worn manhole casting	\$2,875.00
14	West New York Project #5 - #5214 Park Ave - Severely worn manhole casting	\$2,875.00
15	West New York Project #6 - 54th Street & Park Ave MH1 - Severely worn manhole casting	\$2,875.00
16	West New York Project #7 - 54th Street & Park Ave MH2 - Severely worn manhole casting	\$2,875.00
17	West New York Project #8 - 61st Street & Polk Ave NE corner - Collapsed catch basin	\$5,000.00
18	West New York Project #9 - #5805 Jefferson Street - Collapsed manhole	\$15,000.00
	<b>Total:</b>	<b>\$95,125.00</b>

# WORK ORDER REQUEST

DATE: 7/10/2022

WORK ORDER NO. 1 PRIORITY 1

#914 Garden Street Hoboken

PIPE SIZE:

DEPTH OF PIPE:

PIPE MATERIAL:



**DESCRIPTION**

Severely worn manhole casting

**RECOMMENDATION**

Replace manhole casting

APPROVED *Fredric J. Pocci* \_\_\_\_\_

AUTHORITY ENGINEER – NORTH HUDSON SEWERAGE AUTHORITY

# WORK ORDER REQUEST

DATE: 7/10/2022

WORK ORDER NO. 2 PRIORITY 1

10<sup>th</sup> Street & Willow Ave NW corner Hoboken

PIPE SIZE:

DEPTH OF PIPE:

PIPE MATERIAL:



## DESCRIPTION

Catch basin lateral open joint

## RECOMMENDATION

Repair open joint

APPROVED *Fredric J. Pocci* \_\_\_\_\_

AUTHORITY ENGINEER – NORTH HUDSON SEWERAGE AUTHORITY

# WORK ORDER REQUEST

DATE: 7/10/2022

WORK ORDER NO. 3

PRIORITY 1

7<sup>th</sup> Street & Bloomfield Ave SW corner Hoboken

PIPE SIZE:

DEPTH OF PIPE:

PIPE MATERIAL:



## DESCRIPTION

Collapsed catch basin lateral

## RECOMMENDATION

Repair collapsed lateral

APPROVED *Fredric J. Pocci*

AUTHORITY ENGINEER – NORTH HUDSON SEWERAGE AUTHORITY

# WORK ORDER REQUEST

DATE: 7/10/2022

WORK ORDER NO. 1 PRIORITY 1

27<sup>th</sup> Street & Bergenline SE corner Union City

PIPE SIZE:

DEPTH OF PIPE:

PIPE MATERIAL:



## DESCRIPTION

Collapsed catch basin & Lateral

## RECOMMENDATION

Repair catch basin and lateral

APPROVED \_\_\_\_\_  
*Fredric J. Pocci*

AUTHORITY ENGINEER – NORTH HUDSON SEWERAGE AUTHORITY

# WORK ORDER REQUEST

DATE: 7/10/2022

WORK ORDER NO. 2 PRIORITY 1

#112 49<sup>th</sup> Street Union City

PIPE SIZE:

DEPTH OF PIPE:

PIPE MATERIAL:



## DESCRIPTION

Collapsed catch basin lateral

## RECOMMENDATION

Repair collapsed lateral

APPROVED \_\_\_\_\_  
*Fredric J. Pocci*

AUTHORITY ENGINEER – NORTH HUDSON SEWERAGE AUTHORITY



# WORK ORDER REQUEST

DATE: 7/10/2022

WORK ORDER NO. 3

PRIORITY 1

7<sup>th</sup> Street & West Street Union City

PIPE SIZE:

DEPTH OF PIPE:

PIPE MATERIAL:



**DESCRIPTION**

Open joint in mainline

**RECOMMENDATION**

Repair open joint

APPROVED-----*Fredric J. Pocci*-----

**AUTHORITY ENGINEER – NORTH HUDSON SEWERAGE AUTHORITY**

# WORK ORDER REQUEST

DATE: 7/10/2022

WORK ORDER NO. 4

PRIORITY 1

#4312 Bergenline NW corner Union City

PIPE SIZE:

DEPTH OF PIPE:

PIPE MATERIAL:



DESCRIPTION

Catch basin lateral open joint

RECOMMENDATION

Repair lateral open joint

APPROVED \_\_\_\_\_  
*Fredric J. Pocci*

AUTHORITY ENGINEER – NORTH HUDSON SEWERAGE AUTHORITY

# WORK ORDER REQUEST

DATE: 7/10/2022

WORK ORDER NO. 5 PRIORITY 1

26<sup>th</sup> Street & Central Ave NW corner Union City

PIPE SIZE:

DEPTH OF PIPE:

PIPE MATERIAL:



## DESCRIPTION

Collapsed catch basin lateral

## RECOMMENDATION

Repair collapsed lateral

APPROVED *Fredric J. Pocci*

AUTHORITY ENGINEER – NORTH HUDSON SEWERAGE AUTHORITY

# WORK ORDER REQUEST

DATE: 7/10/2022

WORK ORDER NO. 1 PRIORITY 1

#422 Gregory Street Weehawken

PIPE SIZE:

DEPTH OF PIPE:

PIPE MATERIAL:



## DESCRIPTION

Collapsed catch basin lateral

## RECOMMENDATION

Repair collapsed catch basin lateral

APPROVED \_\_\_\_\_  
*Fredric J. Pocci*

AUTHORITY ENGINEER – NORTH HUDSON SEWERAGE AUTHORITY

# WORK ORDER REQUEST

DATE: 7/10/2022

WORK ORDER NO. 1

PRIORITY 1

#427 62<sup>nd</sup> Street West New York

PIPE SIZE:

DEPTH OF PIPE:

PIPE MATERIAL:



DESCRIPTION

Collapsed catch basin

RECOMMENDATION

Repair collapsed catch basin

APPROVED—*Fredric J. Poggi*

AUTHORITY ENGINEER – NORTH HUDSON SEWERAGE AUTHORITY

# WORK ORDER REQUEST

DATE: 7/10/2022

WORK ORDER NO. 2 PRIORITY 1

50<sup>th</sup> Street & Park Ave West New York

PIPE SIZE:

DEPTH OF PIPE:

PIPE MATERIAL:



## DESCRIPTION

Severely worn manhole casting

## RECOMMENDATION

Replace manhole casting

APPROVED \_\_\_\_\_  
*Fredric J. Pocci*

AUTHORITY ENGINEER – NORTH HUDSON SEWERAGE AUTHORITY



# WORK ORDER REQUEST

DATE: 7/10/2022

WORK ORDER NO. 3 PRIORITY 1

#5010 Park Ave West New York

PIPE SIZE:

DEPTH OF PIPE:

PIPE MATERIAL:



## DESCRIPTION

Severely worn manhole casting

## RECOMMENDATION

Replace manhole casting

APPROVED Fredric J. Pocci

AUTHORITY ENGINEER – NORTH HUDSON SEWERAGE AUTHORITY

# WORK ORDER REQUEST

DATE: 7/10/2022

WORK ORDER NO. 4 PRIORITY 1

51<sup>st</sup> Street & Park Ave West New York

PIPE SIZE:

DEPTH OF PIPE:

PIPE MATERIAL:



## DESCRIPTION

Severely worn manhole casting

## RECOMMENDATION

Replace manhole casting

APPROVED *Fredric J. Pocci*

AUTHORITY ENGINEER – NORTH HUDSON SEWERAGE AUTHORITY



# WORK ORDER REQUEST

DATE: 7/10/2022

WORK ORDER NO. 5 PRIORITY 1

#5214 Park Ave West New York

PIPE SIZE:

DEPTH OF PIPE:

PIPE MATERIAL:



## DESCRIPTION

Severely worn manhole casting

## RECOMMENDATION

Replace manhole casting

APPROVED *Fredric J. Pocci*-----

AUTHORITY ENGINEER – NORTH HUDSON SEWERAGE AUTHORITY

# WORK ORDER REQUEST

DATE: 7/10/2022

WORK ORDER NO. 6 PRIORITY 1

54<sup>th</sup> Street & Park Ave West New York

PIPE SIZE:

DEPTH OF PIPE:

PIPE MATERIAL:



## DESCRIPTION

Severely worn manhole casting

## RECOMMENDATION

Replace manhole casting

APPROVED *Fredric J. Pocci* \_\_\_\_\_

AUTHORITY ENGINEER – NORTH HUDSON SEWERAGE AUTHORITY

# WORK ORDER REQUEST

DATE: 7/10/2022

WORK ORDER NO. 7 PRIORITY 1

54<sup>th</sup> Street & Park Ave MH2 West New York

PIPE SIZE:

DEPTH OF PIPE:

PIPE MATERIAL:



**DESCRIPTION**

Severely worn manhole casting

**RECOMMENDATION**

Replace manhole casting

APPROVED *Fredric J. Pocci*

AUTHORITY ENGINEER – NORTH HUDSON SEWERAGE AUTHORITY

# WORK ORDER REQUEST

DATE: 7/10/2022

WORK ORDER NO. 8 PRIORITY 1

61<sup>st</sup> Street & Polk Ave NE corner West New York

PIPE SIZE:

DEPTH OF PIPE:

PIPE MATERIAL:



## DESCRIPTION

Collapsed catch basin

## RECOMMENDATION

Repair collapsed catch basin

APPROVED \_\_\_\_\_  
*Fredric J. Pocci*

AUTHORITY ENGINEER – NORTH HUDSON SEWERAGE AUTHORITY

# WORK ORDER REQUEST

DATE: 7/10/2022

WORK ORDER NO. 9 PRIORITY 1

#5805 Jefferson St West New York

PIPE SIZE:

DEPTH OF PIPE:

PIPE MATERIAL:



## DESCRIPTION

Collapsed manhole

## RECOMMENDATION

Repair collapsed manhole

APPROVED Fredric J. Pocci

AUTHORITY ENGINEER – NORTH HUDSON SEWERAGE AUTHORITY