

**RESOLUTION DIRECTING WORK TO SPINIELLO COMPANIES
UNDER THE COMBINED SEWER MAJOR MISCELLANEOUS REPAIR CONTRACT**

MOTIONED BY: Velazquez
SECONDED BY: Guzman

WHEREAS, the North Hudson Sewerage Authority (hereinafter "Authority) is a public body, duly formed under the Sewerage Authorities law, constituting Chapter 138 of the Laws of New Jersey of 1946, as amended (Chapter 14A of Title 40 of the New Jersey Statutes Annotated) and possesses the powers set forth therein; and

WHEREAS, the Authority has awarded a Combined Sewer Major Miscellaneous Repair contract to combine sewers of various configurations, lengths, sizes materials and their appurtenances; and

WHEREAS, the Authority awarded such a Combined Sewer Major Miscellaneous Repair Contract as required by the New Jersey Contract laws to Spiniello Companies; and

WHEREAS, it is the recommendation of the Authority Engineer that Spiniello Companies, be directed to commence the work as detailed in the attached report prepared by OMI (February 2024 Project), identified as "Exhibit A", for an amount of money estimated at approximately \$80,000.00; and

WHEREAS, the Chief Financial Officer has certified that funding is available through the Authority's Fiscal Year 2023-2024 Operating Budget.


NOW, THEREFORE, BE IT RESOLVED that Spiniello Companies be directed to proceed with the work as herein noted.

DATED: FEBRUARY 15, 2024

RECORD OF COMMISSIONERS' VOTE

| | YES | NO | ABSENT |
|--------------------------|------------|-----------|---------------|
| Commissioner Gardiner | x | | |
| Commissioner Kappock | x | | |
| Commissioner Marotta | | | x |
| Commissioner Friedrich | x | | |
| Commissioner Guzman | x | | |
| Commissioner Velazquez | x | | |
| Commissioner Barrera | x | | |
| Commissioner Zucconi | x | | |
| Commissioner Assadourian | x | | |

**THIS IS TO CERTIFY THAT THIS RESOLUTION WAS DULY ADOPTED BY THE
NORTH HUDSON BOARD OF COMMISSIONERS ON FEBRUARY 15, 2024.**



SECRETARY



February 6, 2024

Donald Conger P.E.
Authority Engineer
North Hudson Sewerage Authority
1600 Adams Street
Hoboken, New Jersey 07030

Subject: Combined Sewer Major Miscellaneous Repair Contracts: 2023-2024
February 2024 Project

Dear Mr. Conger:

The Major Miscellaneous Repair Biennial Contracts: 2024-2026 was awarded to Spinello Companies on January 18, 2024. OMI has prepared a repair project for February 2024. The estimated of these repairs are based on unit prices bid by Spiniello Companies.

Attached is the scope of work and estimated construction costs for the Major Miscellaneous Repair Biennial Contracts: 2023-2024 - February 2024 Project. OMI developed the list based on field inspections, resident concerns, and has estimated quantities and costs for the project.

The proposed February 2024 Project consists of three repairs in Union City and one in hoboken. The construction costs for the four repairs are estimated to be \$80,000.00 and repairs should be completed in four weeks.

If you have any questions or require additional information, please contact me.

Sincerely,

Philip Reeve

Philip G. Reeve
Assistant Project Director

Enclosures

Cc:
Fredric Pocci, NHSA
Kevin Wynn, HMM
Mark Berube, Jacobs

MAJOR MISCELLANEOUS REPAIRS BIENNIAL CONTRACT 2024 - 2026
PROJECT SUMMARY
FEBRUARY 2024 PROJECT
NORTH HUDSON SEWERAGE AUTHORITY
2/12/2024

OWNER: NORTH HUDSON SEWERAGE AUTHORITY
 1600 ADAMS STREET
 HOBOKEN, NJ 07030

CONTRACTOR: Spiniello Companies
 354 Eisenhower PKWY
 Livingston NJ 07039

| PROJECT | DESCRIPTION | ESTIMATED COST |
|---------|---|----------------|
| 1 | Union City Project #1 - #322 35th Street- broken sewermain | \$20,000.00 |
| 2 | Union City Project #2 - 22nd Street btwn Summit & Central - broken sewer main | \$20,000.00 |
| 3 | Union City Project #3 - #1715 Bergenline Avenue- broken sewermain | \$20,000.00 |
| 4 | Hoboken Project #1 - Park Ave south of 4th Street - broken 36 inch sewer main | \$20,000.00 |
| | Total: | \$80,000.00 |

WORK ORDER REQUEST

DATE: 2/12/2024

WORK ORDER NO. 1 PRIORITY 1

#322 35th Street Union City

PIPE SIZE: 25 inch

DEPTH OF PIPE: 8 to 10 feet deep

PIPE MATERIAL: VCP



DESCRIPTION

Broken sewer main 34 feet downstream of the manhole

RECOMMENDATION

Repair broken sewer main

APPROVED _____

AUTHORITY ENGINEER – NORTH HUDSON SEWERAGE AUTHORITY

WORK ORDER REQUEST

DATE: 2/12/2024

WORK ORDER NO. 2 PRIORITY 1

22nd Street between Central and Summit Union City

PIPE SIZE: 12 inch

DEPTH OF PIPE: 8 to 10 feet deep

PIPE MATERIAL: VCP



DESCRIPTION

Broken sewer main 34 feet downstream of the manhole

RECOMMENDATION

Repair broken sewer main

APPROVED

AUTHORITY ENGINEER – NORTH HUDSON SEWERAGE AUTHORITY

WORK ORDER REQUEST

DATE: 2/12/2024


WORK ORDER NO. 4 _____ PRIORITY 1 _____.

Park Ave south of 4th Street Hoboken

PIPE SIZE: 36 inch

DEPTH OF PIPE: 10 to 12 feet deep

PIPE MATERIAL: Brick



DESCRIPTION

Broken sewer main

RECOMMENDATION

Repair broken sewer main

APPROVED _____

AUTHORITY ENGINEER – NORTH HUDSON SEWERAGE AUTHORITY